

# Energy Performance Certificate

## Non-Domestic Building



Carousel Marketing  
Unit 3 Sovereign Court, 8 Graham Street  
Birmingham  
B1 3JR

Certificate Reference Number:  
0620-0831-8910-0396-6006

This certificate shows the energy rating of this building. It indicates the energy efficiency of the building fabric and the heating, ventilation, cooling and lighting systems. The rating is compared to two benchmarks for this type of building: one appropriate for new buildings and one appropriate for existing buildings. There is more advice on how to interpret this information on the Government's website [www.communities.gov.uk/epbd](http://www.communities.gov.uk/epbd).

### Energy Performance Asset Rating

More energy efficient



Net zero CO<sub>2</sub> emissions

**A** 0-25

**B** 26-50

**C** 51-75

**D** 76-100

**E** 101-125

**F** 126-150

**G** Over 150

◀ **61** This is how energy efficient the building is.

Less energy efficient

### Technical information

Main heating fuel: Natural Gas  
Building environment: Heating and Natural Ventilation  
Total useful floor area (m<sup>2</sup>): 190  
Building complexity (NOS level): 3

### Benchmarks

Buildings similar to this one could have ratings as follows:

**36** If newly built

**70** If typical of the existing stock

## Administrative information

This is an Energy Performance Certificate as defined in SI2007:991 as amended

**Assessment Software:** iSBEM v3.4.a using calculation engine SBEM v3.4.a

**Property Reference:** 201968380000

**Assessor Name:** Joe Warren

**Assessor Number:** STRO001137

**Accreditation Scheme:** Stroma Accreditation Ltd

**Employer/Trading Name:** Zero Trace Ltd.

**Employer/Trading Address:** The Cottage on The Hill, Loxley, Warwickshire, CV35 9JS

**Issue Date:** 17 Jun 2009

**Valid Until:** 16 Jun 2019 (unless superseded by a later certificate)

**Related Party Disclosure:**

**Recommendations for improving the property are contained in Report Reference Number: 0960-2096-0411-8630-8000**

## If you have a complaint or wish to confirm that the certificate is genuine

Details of the assessor and the relevant accreditation scheme are on the certificate. You can get contact details of the accreditation scheme from the Government's website at [www.communities.gov.uk/epbd](http://www.communities.gov.uk/epbd), together with details of the procedures for confirming authenticity of a certificate and for making a complaint.



For advice on how to take action and to find out about technical and financial assistance schemes to help make buildings more energy efficient visit [www.carbontrust.co.uk](http://www.carbontrust.co.uk) or call us on **0800 085 2005**